

Product Maintenance for LSQ05A4

Operating Hours				
Inspect	Replace	Description	Quantity	Part Number
Daily		Test Tank Drain	N/A	N/A
Annually		CO Calibration Kit	N/A	N/A
		Dryer Liquid Separator Float	2	ST178519AV
		Dryer Filter Element	4	ST940405AV
5,000		Clean Compressor Fins	N/A	N/A
5,000		Clean After Coolers	N/A	N/A
5,000		Clean Blower Fan and Fan Duct	N/A	N/A
10,000		Temperature and Pressure Sensors	N/A	N/A
10,000		Magnetic Starter	N/A	N/A
		Check Valve	4	IP087700AV
500	5,000	Intake Filter Element	4	VP000543AV
2,500	5,000	Belt	8	BT012001AV
	5,000	Tip Seal / Dust Seal	4	▲ 92832080
	5,000	Heat Insulation Pipe	4	IP602000AV
	5,000	Grease Gun Kit (includes 1 grease)	1	IP616201AJ
	5,000	Grease - 1 tube will grease 3 air ends	1	IP600000AV

▲ For high pressure unit (145 PSI), use tip seal part number 92832080 at 5,000 hours

■ For high pressure units replaced at 5,000 hours

Replace control panel filters annually if applicable

VP000537AV for 5" or VP000538AV for 9" (sold 5 per pack)